


Office of the Executive Engineer
Public Health Engineering Department, Sasaram (Rohtas)
Divisional Laboratory:- Sasaram

(Values In mg /Lit. except pH. Otherwise mentioned)


Zone :- Patna						Division Name: SASARAM													Date:-24/02/2026	
Sl. No.	Block	Panchayat	Mohalla	Name of Habitation/ Ward No.	Location of Source	Parameters														
						pH	Turb	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	No3	So4	F	Total Coli.	
1	Sasaram	Nagar Nigam	Kabir Ganj	Central English School	Tap Water	7.15-	<0.5	206	134	90	18	10.94	20	96	0.1	BDL	10	0.069	Negative	
Desirable Limit						6.5-8.5	1		500	200	75.0	30.00	250-	200	1	45	200	1		
Drinking Water Specification (Second Revision) IS 10500 /2012 Permissible limit in absence of alternate source						NR	5.0-NTU		2000	600	200	100	1000	600	NR	NR	400	1.5		

Note:- Sample collected By - School Staff

BDL- Below detection limit


24/02/2026
 Chemist

P.H.Division.Sasaram


26/02/2026
 Executive Engineer
 P.H.Division.Sasaram